

REQUEST FOR PROPOSAL (RFP)

Addendum #4

470 Bronte Street South, Units 204 & 205, Milton, Ontario

Construction of CMHA HRB and ADAPT Milton Office

Document Version: January 22, 2020

The purpose of the following addendum is to address questions that have arisen during the tendering process. All responses below should be reviewed and incorporated into the bid documents as appropriate.

Upon further review of Addendum #3, question 1 noted below, we have identified that our answer may have caused some confusion.

Questions – January 21, 2020

1. Please provide a communication cabling specification. Please advise what Category of cable is required? Standard installation is CAT6 but some clients are installing CAT6A.



Can we assume that this symbol is (2) cables?

Response: category CAT6. Yes, 2 cables.

Questions – January 22, 2020

1. Can you clarify if CMHA has their own data contractor or the data work is to be included with the electrical?

Clarification:

As per the reference noted below, the items in question will be directly supplied and installed by our data/voice cabling contractor.

E601 18.6. All data and voice cables, inserts, jacks and termination of data and voice cables shall be supplied and installed by tenant's data/voice cabling contractor.

As per the reference noted below, this work is the bidder's responsibility:

E601 18.4. For each data, voice and combination outlet box, provide a ¾" empty conduit from top of outlet box and terminate conduit in accessible ceiling space above, for each combination data/voice outlet, provide a single gang outlet box and a white matching style coverplate.